

C E R T I F I C A T E  
of Conformity



Registration No.: AK 50503879 0001

Report No.: CN213E0E 001

Holder: JIANGSU GOODWE POWER SUPPLY  
TECHNOLOGY CO., LTD.  
No.90 Zijin Rd.,  
New District, Suzhou  
215011 Jiangsu  
P.R. China

Product: PV-Inverter  
(Grid-connected PV Inverter)

Identification: Type Designation: GW100K-HT GW110K-HT  
GW120K-HT GW136K-HTH  
Firmware Version: V1.01.01  
Serial Number : Engnieer Sample  
Remark : Refer to test report CN213E0E 001 for  
details.

Tested acc. to: RD 1699:2011  
UNE 206006 IN:2011  
UNE 206007-1 IN:2013

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date 13.05.2021



Weichun Li

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg



<b>Modelo</b> Model	GW100K-HT	GW110K-HT	GW120K-HT	GW136K-HTH
<b>Potencia nominal CA</b> Nominal AC Power	100 kW	110 kW	120 kW	136 kW
<b>Tensión nominal CA</b> Nominal AC voltage	400 V	400 V	400 V	500 V
<b>Corriente máxima CA</b> Maximal AC current	167.0 A	175.5 A	191.3 A	173.2 A
<b>Frecuencia nominal</b> Nominal frequency	50/60Hz	50/60Hz	50/60Hz	50/60Hz
<b>Rango de tensión MPPT</b> MPPT voltage range	180-1000 V	180-1000 V	180-1000 V	180-1000 V
<b>Tensión CC máxima</b> Max. DC voltage	1100 V	1100 V	1100 V	1100 V
<b>Corriente DC máxima</b> Max. DC current	10*30 A	12*30 A	12*30 A	12*30 A
<b>Elemento de control</b> Control device	Controller in Inverter	Controller in Inverter	Controller in Inverter	Controller in Inverter
<b>Tipo de dispositivo de control</b> Type of control device	Integrated	Integrated	Integrated	Integrated

JIANGSU GOODWE POWER SUPPLY  
TECHNOLOGY CO., LTD.  
Mr. Jiang Tao

Date : 13.05.2021  
Our ref. : HCC 01  
Your ref.: Jiang Tao

No.90 Zijin Rd.,  
New District, Suzhou  
215011 Jiangsu  
P.R. China

**Ref : AK Certificate of Conformity**

Type of Equipment : Grid-connected PV Inverter  
Model Designation : See Certificate  
Certificate No. : AK 50503879 0001  
Report No. : CN213E0E 001

Dear Mr. Jiang Tao,


We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

  
Weichun Li

CC: JIANGSU GOODWE POWER SUPPLY

Enclosure

证书的详细资料请登陆[www.certipedia.com](http://www.certipedia.com)查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询