



Global Access Certification Australia Pty. Ltd.
960 Waverley Road, Wheelers Hill, Victoria 3150, Australia

Proof of RCM Compliance

Certificate No.: RCMP21022 001

Certificate holder: Huawei Technologies Co., Ltd.
Administration Building, Headquarter of Huawei Technologies Co., Ltd., Bantian,
Longgang District, Shenzhen, Guangdong 518129

Product Description: Backup Box

Brand Name: 

Model Number: Backup Box-B0, Backup Box-B1

Electrical Ratings: Backup Box-B0: 220/230Vac, 22.7A;
Backup Box-B1: 380/400Vac, 15.7A
Ui=500V, 50/60Hz, Icw=10kA

GACA approves that this Electrical Article as described above meets the requirements of the standard/regulation(s) listed below:

Complies with	Standard/regulation(s)
ACMA mandated	--
Electrical Safety	AS/NZS 61439.2: 2016, AS/NZS 61439.3: 2016 (Test Report no.: CN217OBX001)
EESS-National Equipment Database Registration	Above models is registered as level 1 product on https://equipment.erac.gov.au/Registration/EquipmentSearch.aspx?atn=public
Date of Registered:	15 January 2021
Date of Expiry:	14 January 2026



On behalf of GACA

