

Certificate of Conformity

Registered No.:

COCPPV04015/22E-01

File reference
PVP04015/22E-03

Test report No.
TRPVP04015/22E/01

Date of issue
2022-05-30

On the basis of the tests undertaken, the samples of the below product(s) have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out:

| | |
|--------------------------------------|--|
| Applicant: | GoodWe Technologies Co., Ltd. No.90 ZiJin Rd., New District, Suzhou, 215011, China |
| Manufacturer: | GoodWe Technologies Co., Ltd. No.90 ZiJin Rd., New District, Suzhou, 215011, China |
| Factory 1: | GoodWe Technologies Co., Ltd. No.90 ZiJin Rd., New District, Suzhou, 215011, China |
| Factory 2: | GoodWe (GuangDe) Power Supply Technology Co., Ltd No.208, Tong Rui East Road, Guangde, Anhui, China |
| Product: | Hybrid Inverter |
| Type designation: | GW5K-ET, GW6.5K-ET, GW8K-ET, GW10K-ET GW5K-BT, GW6K-BT, GW8K-BT, GW10K-BT GW5KN-ET, GW6.5KN-ET, GW8KN-ET, GW10KN-ET |
| Certification program: | BOS-P-01 Rev. 00 |
| Certification fundamental(s): | EN 50549-1:2019 deviations of grid protection settings according to C10/11:2019 edition 2.1 used for Belgium See test report for detailed information. |

This document is based on the evaluation of the samples of the above mentioned product(s). It does not imply an assessment of the mass-production of the product(s), and it does not permit the use of a TÜV NORD mark. The holder of this document may use it in connection with the related test report(s).