



Product Service

Attestation of Conformity

No. N8A 118443 0002 Rev. 00

Holder of Certificate: **Jinko Solar Co., Ltd.**
No.1, Yingbin Road, Economic Development Zone
334100 Shangrao City, Jiangxi
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062217002-05

Date, 2022-10-28

(Zhulin Zhang)

Page 1 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Attestation of Conformity

No. N8A 118443 0002 Rev. 00

Model(s):

JKxxxM-66R5-BGV (xxx=630-665, in steps of 5, 132 cells)
 JKxxxM-66H5-BGV (xxx=635-670, in steps of 5, 132 cells)
 JKMxxxN-78HL4-BDV (xxx=570-625, in steps of 5, 156 cells)
 JKMxxxN-72HL4-BDV, JKMxxxN-72HL4-BDV-J,
 JKMxxxN-72HL4R-BDV, (xxx=480-610, in steps of 5, 144 cells)
 JKMxxxN-66HL4-BDV (xxx=440-520, in steps of 5, 132 cells)
 JKMxxxN-60HL4-BDV (xxx=400-505, in steps of 5, 120 cells)
 JKMxxxN-60HL4R-BDV (xxx=400-505, in steps of 5, 120 cells)
 JKMxxxN-54HL4-BDV (xxx=360-455, in steps of 5, 108 cells)
 JKMxxxN-54HL4R-BDV (xxx=360-455, in steps of 5, 108 cells)
 JKMxxxN-7RL4-BDV, JKMxxxN-7RL4-BDV-J
 (xxx=535-595, in steps of 5, 156 cells)
 JKMxxxN-7TL4-BDV, JKMxxxN-7TL4-BDV-J
 (xxx=495-545, in steps of 5, 144 cells)
 JKMxxxN-6RL4-BDV (xxx=455-500, in steps of 5, 132 cells)
 JKMxxxN-6TL4-BDV (xxx=415-455, in steps of 5, 120 cells)
 JKMxxxN-5RL4-BDV (xxx=375-410, in steps of 5, 108 cells)
 JKMxxxM-72H-DV (xxx=390-415, in steps of 5, 144 cells)
 JKMxxxM-60H-DV (xxx=325-345, in steps of 5, 120 cells)
 JKMxxxM-7RL4-BDVP, JKMxxxM-7RL4-BDVP-J
 (xxx=535-595, in steps of 5, 156 cells)
 JKMxxxM-72HL4-BDVP, JKMxxxM-72HL4-BDVP-J
 (xxx=500-565, in steps of 5, 144 cells)
 JKMxxxM-66HL4-BDVP (xxx=460-500, in steps of 5, 132 cells)
 JKMxxxM-60HL4-BDVP (xxx=420-455, in steps of 5, 120 cells)
 JKMxxxM-54HL4-BDVP (xxx=375-410, in steps of 5, 108 cells)
 JKMxxxM-7TL4-BDVP, JKMxxxM-7TL4-BDVP-J
 (xxx=500-545, in steps of 5, 144 cells)
 JKMxxxM-6RL4-BDVP (xxx=460-500, in steps of 5, 132 cells)
 JKMxxxM-6TL4-BDVP (xxx=420-455, in steps of 5, 120 cells)
 JKMxxxM-5RL4-BDVP (xxx=375-410, in steps of 5, 108 cells)
 JKMxxxM-72HL-BDV (xxx=390-410, in steps of 5, 144 cells)
 JKMxxxM-72H-BDV (xxx=390-410, in steps of 5, 144 cells)
 JKMxxxM-60HL-BDV (xxx=325-340, in steps of 5, 120 cells)
 JKMxxxM-60H-BDV (xxx=325-340, in steps of 5, 120 cells)
 JKMxxxM-72H-MBB-BDV (xxx=390-415, in steps of 5, 144 cells)
 JKMxxxN-60H-MBB-BDV (xxx=330-345, in steps of 5, 120 cells)
 JKMxxxM-72HL-BDVP (xxx=375-430, in steps of 5, 144 cells)
 JKMxxxM-72H-BDVP (xxx=375-430, in steps of 5, 144 cells)
 JKMxxxM-60HL-BDVP (xxx=310-355, in steps of 5, 120 cells)
 JKMxxxM-60H-BDVP (xxx=310-355, in steps of 5, 120 cells)
 JKMxxxM-72H-MBB-BDVP (xxx=380-415, in steps of 5, 144 cells)
 JKMxxxM-60H-MBB-BDVP (xxx=315-345, in steps of 5, 120 cells)
 JKSN3-DDCA-xxx (xxx=405-435, in steps of 5, 156 cells)
 JKSN3-CDCA-xxx (xxx=345-365, in steps of 5, 132 cells)
 JKSM3-DDCA-xxx (xxx=405-430, in steps of 5, 156 cells)
 JKSM3-CDCA-xxx (xxx=345-360, in steps of 5, 132 cells)
 JKMxxxN-78H-BDV (xxx=415-460, in steps of 5, 156 cells)
 JKMxxxN-66H-BDV (xxx=350-385, in steps of 5, 132 cells)
 JKMxxxN-7RL3-BDV (xxx=440-490, in steps of 5, 156 cells)
 JKMxxxN-6RL3-BDV (xxx=375-410, in steps of 5, 132 cells)
 JKMxxxM-78H-BDVP (xxx=415-455, in steps of 5, 156 cells)
 JKMxxxM-66H-BDVP (xxx=350-385, in steps of 5, 132 cells)
 JKMxxxM-7RL3-BDVP, JKMxxxM-7RL3- BDVP-J
 (xxx=440-465, in steps of 5, 156 cells)
 JKMxxxM-6RL3- BDVP, JKMxxxM-6RL3- BDVP-J
 (xxx=375-390, in steps of 5, 132 cells)

Page 2 of 3

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Attestation of Conformity

No. N8A 118443 0002 Rev. 00

JKMxxxM-78HL3-BDVP, JKMxxxM-78HL3-MBB-BDVP
 (xxx=450-480, in steps of 5, 156 cells)
 JKMxxxM-66HL3-BDVP, JKMxxxM-66HL3-MBB-BDVP
 (xxx=380-405, in steps of 5, 132 cells)
 JKMxxxM-72HLM-BDVP (xxx=415-460, in steps of 5, 144 cells)
 JKMxxxM-60HLM-BDVP (xxx=345-380, in steps of 5, 120 cells)
 JKMxxxM-72L-BDV (xxx=375-405, in steps of 5, 72 cells)
 JKMxxxM-72-BDV (xxx=375-405, in steps of 5, 72 cells)
 JKMxxxM-60L-BDV (xxx=310-335, in steps of 5, 60 cells)
 JKMxxxM-60-BDV (xxx=310-335, in steps of 5, 60 cells)
 JKMxxxM-72L-BDVP (xxx=370-410, in steps of 5, 72 cells)
 JKMxxxM-72-BDVP (xxx=370-410, in steps of 5, 72 cells)
 JKMxxxM-60L-BDVP (xxx=305-340, in steps of 5, 60 cells)
 JKMxxxM-60-BDVP (xxx=305-340, in steps of 5, 60 cells)
 JKMxxxM-72-DV (xxx=385-405, in steps of 5, 72 cells)
 JKMxxxM-78HL4-BDVP (xxx=570-595, in steps of 5, 156 cells)
 JKBSxxxN-48HL4-BDV (xxx=355-380, in steps of 5, 96 cells)
 JKBSxxxN-22.5HL4-BDV (xxx=165-180, in steps of 5, 45 cells)
 JKBSxxxM-48HL4-BDVP (xxx=335-375, in steps of 5, 96 cells)
 JKBSxxxM-22.5HL4-BDVP (xxx=160-175, in steps of 5, 45 cells)
 JKMxxxN-60HL4-MDV (xxx=450-470, in steps of 5, 120 cells)
 JKMxxxN-54HL4-MDV (xxx=405-420, in steps of 5, 108 cells)
 xxx is standing for rated output power at STC

Parameters:

Fire Safety Class:	Class A or C according to UL790.
Safety Class:	Class II
Max. System Voltage:	1500V DC
Construction:	Framed or frameless, double glass with Junction box, cable and connector.

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06